

Government of Bihar
Public Health Division Muzaffarpur
Water Quality Testing Report


Received Sample on date : 10.06.2024


District - Muzaffarpur				Testing date - 10.06.2024				Sample Collected by : School Staff								
SL. No.	Block	Location of Source	Type of Source	Parameters tested												
				pH	Turbidity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic	Total Coll.
1	Mushahri	Adarsh Vidya Mandir	Boring water	-	1	223	71.4	20	30	304	0.18	3.20	8	0.74	-	< 1.1
Desirable Unit				6.5 - 8.5	1	200	75	30	250	200	0.3 mg/l	45 mg/l	200	1.00	0.01 mg/l	-
Maximum Permissible limit in absence of alternate source				NR	5 NTU	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	1 mg/l	NR	400 mg/l	1.5 mg/l	NR	-


Memo No. - 73 Muzaffarpur, Dated - 10/06/2024

Copy to Principal Adarsh Vidya Mandir, Sikandarpur Main Road, Muzaffarpur, to inform regarding reference to his letter No. - AVM/36-2024

Dated :-10.06.2024


Lab Assistant


Chemist


Assistant Engineer

P.H. Division, Muzaffarpur

**ASSISTANT ENGINEER
PH DIVISION
MUZAFFARPUR**