

Government of Bihar
Public Health Engineering Department

Public Health Engineering Department																			
DISTRICT :- SAMASTIPUR			DIVISION :- SAMASTIPUR																
S.N.			BLOCK			LOCATION OF SOURCE			PARAMETERS										REMARKS
									pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe	
1	SINGHIYA	NEW HOLY MISSION SR. SEC SCHOOL	7.2	1	145	94	48	32	24	12	52	0.2	-Ve						
Acceptable Limit as per BIS 10500/2012			6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250mg/l	30 mg/l	200 mg/l	1.0mg/l							
Permissible Limit* in Absence of Alternate source as per BIS 10500/2012			NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR							

ANALYST:
P.H DIVISION - SAMASTIPUR



28/06/25
(Signature)