

DISTRICT LEVEL WATER TESTING LABORATORY P.H.DIVISION, MADHUBANI

Letter No-LAB/MDB/MARCH/37

Date of Sampling-23/03/2026

Testing Date:- 24/03/2026

Months:- March. 2026

Sample Collected & Submitted by Lab staff.

Sl No	Block	Panchayat	Village/Town	Source of Water	Name of Location/ Nearest Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	TDS	EC	BACTERIA	Remarks
1	Jaynagar	Jaynagar	Town	Boring	Don Bosco English School.Jaynagar.	7	0.5	146	200	24	8	15	0.2	0.1	163	256	A	
Min-Max-Permissible Limit						6.5 - 8.5	1.0-05	200 - 600	200 - 600	75 - 200	30 - 100	250 - 1000	1.0	0.5 - 1.5	500 - 2000		Absent/Present	

*BDL- Below Detection Limit

*A - Absent

NOTE:- THIS TEST REPORT IS VALID FOR ONLY 06 MONTHS (Pre-monsoon & Post-monsoon) FROM THE DATE OF TESTING

(Signature)
24/03/2026

Lab Assistant

District Level Laboratory, Madhubani

(Signature)
24/03/2026

Chemist

District Level Laboratory, Madhubani