

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 09

Dated: 10.03.2026

It is certified that an inspection team headed by ANIL KUMAR (CHEMIST)

(Name of Officers with designation) from DLWTL, P.H. DIVISION, Bettiah PHED

inspected the LOTUS PUBLIC SCHOOL, NARKATIAGANJ

(Name & Address of the school) on 09.03.2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 06 dated 07.03.2026

of DLWTL, P.H. Division, Bettiah (PHED Lab) certified that the

LOTUS PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal: Anil Kr. 10/03/2026

Name: ANIL KUMAR

Designation: CHEMIST

Name & Address of the Office / Department: P.H. Division, Bettiah.

To LOTUS PUBLIC SCHOOL  
SHIVGANJ, SHIKARPUR, NARKATIAGANJ.  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

District Level Water Testing Laboratory P.H.Division, Bettiah

# PUBLIC HEALTH DIVISION, BETTIAH

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON 05/03/2026 BY Mr. Aditya Ratan & RECEIVED IN THE LABORATORY ON 05/03/2026

Sl. NO	PARTICULARS OF THE SAMPLE				PARAMETERS EXAMINED (VALUE IN Mg/l except pH. Otherwise Mentioned)														
	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkanity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test
1	Narkatiya gony	Nagar Parishad	Skivgony, Shikarpur	Lotus Public School	0.97	7.3	361	142	156	36	12	21	10	0.2	0.0	0.3	241	NT	Neg.
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5-8.5	200-600	200-600	75-200	30-100	250-1000	200-400	1.0-1.5 NR	45-100 NR	1-1.5	500-2000	0.01-0.05 NR	+VE -VE	

Remarks-- *Analysed parameters of above sample is within permissible limit.*

Memo No. 06 dated 07/03/2026

Signature *Anil Kumar*  
**CHEMIST**  
 DLWTL  
 P.H. Division, Bettiah