



प्राथमिक स्वास्थ्य केन्द्र मड़वन, मुज०

PRIMARY HEALTH CENTER MARWAN (MUZ)
Pin-843113, Tel.-9102606724, Email:phcmarwan1@gmail.com



Letter No...190.....

Date...13-09-24.....

Health And Sanitation Certificate

On Written Request of Director and Principal of Anand Prep\public School, Mansurpur Chamarua, Ps-Karja, Block-Marwan, Dist- Muzaffarpur. I Visited the School Today on Dated 13.09.2024 Regarding Health and Sanitation.

So far as Health and Sanitation is Concerned. I Found Satisfactory.

Manolis
13/9/24
Incharge Medical Officer
Primary Health Centre, Marwan
Muzaffarpur



**OFFICE OF THE EXECUTIVE ENGINEER
P.H. DIVISION, MUZAFFARPUR**

Letter No: 39/

Dated: 10/9/24

REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

Certificate

It is certified that an inspection team headed by Sri Satya Prakash Azad, Chemist from Public Health Division, Muzaffarpur inspected the ANAND PREP / PUBLIC SCHOO, Mansurpur, Chamarua, P.S.-Karza, District- Muzaffarpur-842001, on 30/08/2024 and found that the ANAND PREP / PUBLIC SCHOO has safe drinking water facilities for the students and member of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central/state/U.T Govt.

The above valid for a period of one year.

TO,
ANAND PREP / PUBLIC SCHOO
Mansurpur, Chamarua P.S.-Karza, Muzaffarpur-842001

S.P. Azad
16/9/24
CHEMIST
R.W.T.L. Muzaffarpur
R.W.T.L. MUZAFFARPUR

PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Quality Test Report

Division Name :- P. H. Division, Muzaffarpur

District Name : Muzaffarpur

Month : Septembar 2024

Name of the School :- ANAND PREP / PUBLIC SCHOOL

Sl. No.	Testing Date	Block	Panchayat	Village	Habitation / Ward	Location of Source	pH	Turb.	Cond.	TDS	TH	Ca	Mg	Cl	Alk	Fe	No ₃	So ₄	F	As	Total Cell	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	02.09.2024	Marwan	Makdumpur Kodaria	Mansurpur	-	Mansurpur Chamarua, P.S - Karza, Muzaffarpur	7.02	0.98	490	319	200	46.8	15	38	205	0.29	0.72	10	0.2	-	-	
Desirable Limit **							6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	###	-	
Pesrmissible Limit* in absence source (IS 10500-2012 - 2nd Revision)							NR	5.0		2000	600	200	100	1000	600	0.1	NR	400	1.5	NR	-	

S.P. A. P.
 Chemist
 RWTL, Muzaffarpur

