

APPENDIX - VIII

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 04

Date : 12.05.2026

It is certified that an inspection team headed by ANIL KUMAR,
Chemist (Name of Officers
with designation) from DLWTL, P.H. DIVISION, BETTIAH (Name of
Department/Office) inspected the CARMEL CONVENT, Basgaon,
Bhairoganj, Bagaha-I (Name & Address of
the School) on 11.05.2026 and found that the CARMEL CONVENT
Basgaon, Bhairoganj, Bagaha-I (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year.

Signature with Seal : Anil K.
12/05/2026
Name : ANIL KUMAR
Designation : CHEMIST P.H. Division, Bettiah.

To

CARMEL CONVENT
BASGAON, Bhairoganj
Bagaha-I

(Name & Address of the Institution)

District Level Water Testing Laboratory P.H.Division, Bettiah

PUBLIC HEALTH DIVISION, BETTIAH

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES
 SAMPLE COLLECTED ON 07/05/2026 BY Mr. Raushan Kumar & RECEIVED IN THE LABORATORY ON 07/05/2026

| Sl. NO | PARTICULARS OF THE SAMPLE | | | | PARAMETERS EXAMINED (VALUE IN Mg/L except pH. Otherwise Mentioned) | | | | | | | | | | | | | | |
|---|---------------------------|----------------|----------------------|--|--|------------|--------------|----------------|------------------|-----------|-----------|-------------|------------|-----------|----------|----------|-------------|------------|----------------------|
| | Block | Gram Panchayat | Village/ Ward Number | Name of the Nearest person/Institution | Turbidity | pH | Conductivity | Total Hardness | Total Alkalinity | Calcium | Magnesium | Chloride | Sulphate | Iron | Nitrate | Flouride | T.D.S | Arsenic | Bacteriological test |
| 1. | Bagaha-1 | Bhairoganj | Bansgaon | Carmel Convent | 0.97 | 7.3 | 363 | 138 | 148 | 32 | 11 | 20 | 10 | 0.2 | 0.0 | 0.3 | 242 | NT | Neg. |
| Min-Max Permissible Limit (IS:10500/2012) | | | | | 1-5 NTU | 6.5 8.5 | | 200 600 | 200 600 | 75 200 | 30 100 | 250 1000 | 200 400 | 1.0 NR | 45 NR | 1 1.5 | 500 2000 | 0.01 NR | +VE -VE |

Remarks- Analysed parameters of above sample is within permissible limit.

Memo No.: 03 dated: 09.05.2026

Anil K.
 Signature of 09/05/2026 Chemist
CHEMIST
DLWTL
 P.H. Division, Bettiah.