

DISTRICT LEVEL LABORATORY, CHAPRA (SARAN)

# PUBLIC HEALTH DIVISION, CHAPRA

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON-10-04-2026- BY-CHANDAN KUMAR & RECEIVED IN THE LABORATORY ON-10-04-2026

Sl. NO	PARTICULARS OF THE SAMPLE				PARAMETERS EXAMINED (VALUE IN Mg/L except pH. Otherwise Mentioned)														
	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test
1	CHAPRA			CENTRAL PUBLIC SCHOOL AFFILIATED TO C.B.S.E NEW DELHI UP TO 10+2, VIKAS NAGAR , CHANDMARI ROAD CHAPRA- 841302	2	8.3	473	130	160	40	9.6	20	15	0.1	0	0.1	284	SDI	Neg
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5 8.5	-	200 600	200 600	75 200	30 100	250 1000	200 400	1.0 NR	45 NR	1 1.5	500 2000	0.01 NR	+VE -VE

Remarks- Analysed parameters of above sample is within permissible limit.

Memo No 063 / Chapra, Dated 11-04-2026.

Vijay Kumar  
 11/04/2026  
 Signature of the Chemist  
 Chemical  
 D&WQTL  
 P.H Division, Chapra

