


PUBLIC HEALTH ENGINEERING DEPARTMENT
Regional Water Testing Laboratory

District Name : Muzaffarpur

Month - April 2026

Sl No	Block	Panchayat	Village	Ward	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alk	Fe	So ₄	NO ₃	F	As	MPN	Remarks
1	Murali	Pikhi Gajpati	Mohammadpur Kothi Campus	-	Blue Sky Public School	6.99	1	470	190	140	11.4	11.70	32	110	0.2	15	5	0.2	BDL	NIL	
Acceptable Limit (IS 10500-2012)						6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	1.0 mg/l	200 mg/l	45 mg/l	1.0 ppm	0.01 ppm	0.01 mg/l	
Permissible Limit in absence of alternate source (IS 10500-2012)						NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NR	400 mg/l	NR	1.5 ppm	NR	0.1 mg/l	


 Chemist
 RWTL Muzaffarpur
 5/10/26