

**PERFOMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 432Date: 30-06-2026

It is certified that an Inspection Team headed by Amit Kumar, Research Assistant, P.H.E.D., Samastipur (Name of Officer with designation), from the Public Health Division, Samastipur (Name of Department/Officer), inspected the **NEW HOLY MISSION SR. SEC. SCHOOL SINGHIYA**, Samastipur (Name & Address of the School) on **25/06/2026** and found that the school, **NEW HOLY MISSION SR. SEC. SCHOOL SINGHIYA**, Samastipur, has safe drinking water facilities for the students and members of staff of the institution and is maintaining hygienic sanitation conditions in the school building and campus as per the norms prescribed by the Central/State/U.T. Government.

Signature with seal:

[Signature]
Executive Engineer
P.H.E.D.
Samastipur

Name: Kumar AbhishekDesignation: Executive Engineer

To,

The Principal,**NEW HOLY MISSION SR. SEC. SCHOOL****SINGHIA, SAMASTIPUR****BIHAR, PIN – 848209***(Name & Address of the Institution)*

DISTRICT – SAMASTIPUR

Government of Bihar
Public Health Engineering Department
SU3 DIVISION – ROSERA

MONTH – JUNE-2026

SL.NO.	BLOCK	NAGAR PANCHAYAT	WARD	LOCATION	Parameters										Remarks
					PH	EC	TDS	TH	Cl	Fe	Alka	NO3	Turb	SO4	
1	SINGHIYA	SINGHIYA	15	NEW HOLY MISSION SR. SEC.SCHOOL SINGHIYA	7.1	209	136	68	22	0.2	56	1.5	1	8	
Acceptable Limit as per BIS 10500/2012					6.5-8.5	-	500mg/l	200mg/l	250mg/l	1.0mg/l	200mg/l	45	1 NTU	200mg/l	
Permissible Limit *In Absence of Alternate source as per BIS10500/2012					NR	-	2000mg/l	600mg/l	1000mg/l	NR	600mg/l	NR	1 NTU	400mg/l	

CHEMIST

P.H DIVISION SAMASTIPUR

EXECUTIVE ENGINEER

P.H DIVISION SAMASTIPUR

36/6/24
Executive Engineer
P.H.E.D.
Samastipur