

47199 - PHE/78/26

Government of Bihar
Public Health Engineering Department

DISTRICT :- SAMASTIPUR			DIVISION :- SAMASTIPUR										MONTH:-AUGUST 2026				
S.N.	BLOCK	LOCATION OF SOURCE	PARAMETERS												REMARKS		
			pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe	T.COUL				
1	SAMASTIPUR	MOUNT CARMEL INT SCHOOL	7.1	1	188	122	54	16	22	9	58	0.1	-Ve				
Acceptable Limit as per BIS 10500/2012			6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250mg/l	30 mg/l	200 mg/l	1.0mg/l		-			
Permissible Limit* in Absence of Alternate source as per BIS 10500/2012			NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR		-			

Soni
19/8/26
Chemist / Lab Assistant
P.H. Division Samastipur
Dist. Samastipur